

FILE NO. 031880

ORDINANCE NO.

22-04

1 [Ordinance amending San Francisco Fire Code to require self-contained breathing  
2 replenishment systems in high rise buildings.]

3 **Ordinance amending San Francisco Fire Code by adding Section 9001.1.4 to require**  
4 **self-contained breathing replenishment systems in high rise buildings where permits**  
5 **have been issued after March 30, 2004.**

6  
7 Note: Additions are single-underline italics Times New Roman;  
8 deletions are ~~strikethrough italics Times New Roman~~.  
9 Board amendment additions are double underlined.  
10 Board amendment deletions are ~~strikethrough normal~~.

11 Be it ordained by the People of the City and County of San Francisco:

12 Section 1. The San Francisco Fire Code is hereby amended by amending Section  
13 9001.1.4, to read as follows:

14 Sec. 1. The San Francisco Fire Code is hereby amended by adding Section 9001.1.4  
15 Section 9001.1.4. Local Standards for High Rise Buildings and Tunnels.

16 A self-contained breathing air replenishment system shall be installed in all buildings  
17 having floors used for human occupancy located more than 75 feet (22 860 mm) above the  
18 lowest level of fire department vehicle access. This requirement shall apply for all buildings  
19 meeting this definition when the building permit application for construction was made after  
20 March 30, 2004.

21 A self-contained breathing air replenishment system will provide a supply of  
22 pressurized breathing air through a permanently installed piping distribution system for the  
23 replenishment of portable breathing air equipment.

24 The self-contained breathing air replenishment system shall be installed in all new  
25 underground transportation or pedestrian tunnels exceeding 300 feet (91 440 mm).

Supervisors Dufty, Daly, Hall, Peskin, Ma  
\*\*Name of Supervisor/Committee/Department\*\*  
BOARD OF SUPERVISORS

1           The self-contained breathing air replenishment system shall meet the specifications set  
2 forth in Appendix VI-J, Section 7.08 Self-Contained Breathing Air Replenishment System.  
3

4  
5 APPROVED AS TO FORM:  
6 DENNIS J. HERRERA, City Attorney

7 By: Please see original in file for signature  
8 Margaret W. Baumgartner  
9 Deputy City Attorney  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

23 Supervisors Bevan Dufty, Chris Daly  
24  
25

\*\*Name of Supervisor/Committee/Department\*\*  
BOARD OF SUPERVISORS



# City and County of San Francisco

City Hall  
1 Dr. Carlton B. Goodlett Place  
San Francisco, CA 94102-4689

## Tails Ordinance

**File Number:** 031880

**Date Passed:**

Ordinance amending San Francisco Fire Code by adding Section 9001.1.4 to require self-contained breathing replenishment systems in high rise buildings where permits have been issued after March 30, 2004.

---

January 13, 2004 Board of Supervisors — SUBSTITUTED

February 3, 2004 Board of Supervisors — AMENDED

Ayes: 11 - Alioto-Pier, Ammiano, Daly, Dufty, Gonzalez, Hall, Ma, Maxwell,  
McGoldrick, Peskin, Sandoval

February 3, 2004 Board of Supervisors — PASSED ON FIRST READING AS AMENDED

Ayes: 11 - Alioto-Pier, Ammiano, Daly, Dufty, Gonzalez, Hall, Ma, Maxwell,  
McGoldrick, Peskin, Sandoval

February 10, 2004 Board of Supervisors — FINALLY PASSED

Ayes: 10 - Alioto-Pier, Ammiano, Daly, Dufty, Gonzalez, Hall, Ma, Maxwell,  
McGoldrick, Peskin  
Absent: 1 - Sandoval

File No. 031880


I hereby certify that the foregoing Ordinance was FINALLY PASSED on February 10, 2004 by the Board of Supervisors of the City and County of San Francisco.

Feb 19 2004

\_\_\_\_\_  
Date Approved



\_\_\_\_\_  
Gloria L. Young  
Clerk of the Board

  
\_\_\_\_\_  
Mayor Gavin Newsom